

No.5/2/MISC/2020-FS/KPI-03
GOVERNMENT OF MANIPUR
FIRE SUB-STATION, KANGPOKPI



Kangpokpi, the 11th June, 2021

"TO WHOM IT MAY CONCERN"

This is to certify that the "EKLAVYA MODEL RESIDENTIAL SCHOOL" located at Gamnom Sapormeina, Kangpokpi District, Manipur had been inspected by this department on 10th June, 2021 and reported that Fire Precautionary measure taken up by the authority is found satisfactorily and the concerned employees are also well acquainted on care and handling of First Aid Fire Fighting Equipments.

It is also advised to the School Authority for taking follow-up action to the following:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life and property due to non functional fire safety measures shall be at the responsibility of the management.
3. Fire Fighting training & mock drill exercise shall be organized quarterly half yearly with intimation of Fire Service Department.
4. The trained Fire Fighting staff should be available round the clock.
5. Any deviation with construction etc. shall be verified by the concerned building sanctioning authority.
6. Water Source of Fire Fighting purposes shall be available in the school premises throughout the year.
7. All exits provided in the School building shall be kept free from any obstruction.
8. First Aid Kits and necessary medicines are readily available in the school.
9. Fire Emergency Telephone numbers shall be displayed on the notice board.
10. School buildings shall be insured against fire and natural calamities with group insurance of School Pupils.
11. If the School Authority failed to conform the above conditions, this NOC so issued shall be treated as cancelled.

Hence, this Department has got "NO OBJECTION" for a period of 1(one) year's time from the date of issue of this certificate in favour of the "EKLAVYA MODEL RESIDENTIAL SCHOOL" for running the School by the concerned authority in their own building subject to compliance of the above conditions.

Officer-in-Charge,
Fire Sub-Station,
Kangpokpi
Officer In-Charge
FIRE SUB-STATION
Kangpokpi